



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

Steep Falls Elementary School  
781 Boundary Road  
Steep Falls, ME 04085

Date Printed: 09/01/2021  
Work Order #: 2108-04683  
Client Job #: 598  
Date Received: 08/27/2021  
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 09/01/2021  
CLIENT NAME: Steep Falls Elementary School

CLIENT ADDRESS: 781 Boundary Road  
Steep Falls, ME 04085

METHOD: EPA 200.8  
EPA ACTION LEVEL: 15 ppb  
MAINE GUIDELINE: 4 ppb  
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 08/27/2021 09:30AM  
ANALYSIS PACKAGE: Maine Schools-Lead  
RECEIPT TEMPERATURE: 22° CELSIUS  
CLIENT JOB #: 598

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Last Used	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2108-04683-001	Kitchen food prep sink	I	KF	08/25/2021 03:00PM	1.5	ppb			DR-NH	08/31/2021 04:41PM
2108-04683-002	Fountain in cafeteria	I	DWF	08/25/2021 03:00PM	11.3	ppb			DR-NH	08/31/2021 04:44PM
2108-04683-003	Fountain across from cafeteria	I	DWF	08/25/2021 03:00PM	<1	ppb			DR-NH	08/31/2021 04:47PM
2108-04683-004	Fountain between restrooms	I	DWF	08/25/2021 03:00PM	1.8	ppb			DR-NH	08/31/2021 04:50PM
2108-04683-005	Faucet in clinic	I	O	08/25/2021 03:00PM	14.5	ppb			DR-NH	08/31/2021 05:02PM
2108-04683-006	Faucet room 6	I	O	08/25/2021 03:00PM	7.8	ppb			DR-NH	08/31/2021 05:04PM
2108-04683-007	Fountain room 6	I	DWF	08/25/2021 03:00PM	17.9	ppb			DR-NH	08/31/2021 05:07PM
2108-04683-008	Faucet room 7	I	O	08/25/2021 03:00PM	7.0	ppb			DR-NH	08/31/2021 05:10PM
2108-04683-009	Fountain room 7	I	DWF	08/25/2021 03:00PM	9.2	ppb			DR-NH	08/31/2021 05:13PM
2108-04683-010	Faucet room 8	I	O	08/25/2021 03:00PM	4.9	ppb			DR-NH	08/31/2021 05:16PM
2108-04683-011	Fountain room 8	I	DWF	08/25/2021 03:00PM	14.9	ppb			DR-NH	08/31/2021 05:25PM
2108-04683-012	Faucet room 9	I	O	08/25/2021 03:00PM	18.3	ppb			DR-NH	08/31/2021 05:28PM
2108-04683-013	Fountain room 9	I	DWF	08/25/2021 03:00PM	28.0	ppb			DR-NH	08/31/2021 05:36PM
2108-04683-014	Faucet room 22	I	O	08/25/2021 03:00PM	9.8	ppb			DR-NH	08/31/2021 05:39PM
2108-04683-015	Fountain room 22	I	DWF	08/25/2021 03:00PM	34.2	ppb			DR-NH	08/31/2021 05:42PM
2108-04683-016	Faucet room 23	I	O	08/25/2021 03:00PM	49.4	ppb			DR-NH	08/31/2021 05:45PM
2108-04683-017	Fountain room 23	I	DWF	08/25/2021 03:00PM	5.4	ppb			DR-NH	08/31/2021 05:48PM
2108-04683-018	Faucet room 24	I	O	08/25/2021 03:00PM	4.5	ppb			DR-NH	08/31/2021 05:51PM
2108-04683-019	Fountain room 24	I	DWF	08/25/2021 03:00PM	27.0	ppb			DR-NH	08/31/2021 05:54PM
2108-04683-020	Faucet room 25	I	O	08/25/2021 03:00PM	9.0	ppb			DR-NH	08/31/2021 05:57PM
2108-04683-021	Fountain room 25	I	DWF	08/25/2021 03:00PM	61.4	ppb			DR-NH	08/31/2021 06:14PM

Rebecca L. Labranche  
Laboratory Director